

Secondary Drinking Water Regulations

Contaminants	SMCL, mg/L
Aluminum	0.05 to 0.2 depending on case-by-case circumstances
Chloride	250
Color	15 color units
Copper	1.0
Corrosivity	Non – corrosive
Fluoride	2.0
Foaming Agents(MBAS) (Methylene Blue Active Substances)	0.5
Hexachlorocyclopentadiene	0.008(P)*
Iron	0.3
Manganese	0.05
Odor	3 threshold odor number
pH	6.5-8.5
Silver	0.1
Sulfate	250
Total Dissolved Solids (TDS)	500
Zinc	5

(P)* = Proposed

SMCL, (mg/L) = Secondary Maximum Contaminant Level expressed in milligrams per liter (unless otherwise specified).